



MP-... 4 100

Insulating mat class 4 - width 1 m.

Application :

CATU Electrical Insulating Mats conform to IEC 61111:2009 and are manufactured using high quality elastomer rubber in order to provide complete protection against electric shock, isolating users from potentially life-threatening electrical currents..

CATU Electrical Insulating Mats are suitable for use in outdoor and indoor applications and are generally placed in front of electrical panels, switch gears & high voltage equipment in order to create a safe working environment for the operators/users.

The choice of the class must be determined according to the maximal nominal voltage of the network.

Rigorous testing to conform to the IEC 61111:2009 standard includes:

- Puncture resistance test
- Flame retardance test
- Dielectric test
- Acid resistance test
- Ageing test
- Oil resistance test

Features :

- · Insulating mat for live and dead working.
- Class 4 Maximum operating voltage: 36 000 V AC 54 000 V DC.
- Used to cover the floor for the electrical protection of operators in electrical installations.
- Protect the workers from the ground potential.
- · Must be adapted to the nominal voltage of the network supplying the installation on which it is used.
- In accordance with IEC 61111:2009 standard and to specific properties of the "C" Category (extremely low temperature folding test at -40 °C).
- RoHS2 compliant. REACH compliant (SVHC free).
- Material: elastomer, halogen free. .
- Thickness: 5mm +/-0.2mm.
- D bar code (Datamatrix) on marking with direct link to user guide and technical sheet.
- Storage temperature: +10°C to +21°C.
- Operating temperature: -40°C to +55°C.





Last Modification : 04/20/2025

CATU S.A.S. - 10, Avenue Jean-Jaurès - B.P.2 - 92222 Bagneux Cedex France







Reference	Class	Voltage		Dimensions			
		Operating Voltage AC	Operating Voltage DC	Length (mm)	Width (mm)	Thickness (mm)	Weight (kg)
MP-100/05-5	4	36 000 V	54 000 V	5 000	1 000	5	44,5

Last Modification : 04/20/2025



UID : | TID : :: 05/03/2025| SID : :: 05/03/2025 | Issued :05/03/2025 04:43:13 am