

CG-Accessories...

Pneumatic tester for insulating gloves

Application:

- For compulsory control of insulating gloves before use.
- Checking is done by inflating and immersing in water the insulating gloves.
- Device recommended by standard IEC 60903:2014 for the periodic testing of insulating gloves from class 00 to 4

Features:

- Body of molded thermosetting material resting on a circular collar and comprising a frustoconical tip with two grooves for receiving the glove to be tested.
- Central piston located at the base of the unit.
- Soft valve located at the bottom of the bowl, at the top.
- Maintenance of the insulating glove in position when inflated by two elastic rings



Reference	Longueur (mm)	Longueur
	Length (mm)	Dimensions
CG-117	140	