



MP-... 0_100

Insulating mat class 0 – width 1 m

Application :

CATU Electrical Insulating Mats conform to IEC 61111:2009 and are manufactured using high quality elastomer rubber in order to provide complete protection against electric shock, isolating users from potentially life-threatening electrical currents..

CATU Electrical Insulating Mats are suitable for use in outdoor and indoor applications and are generally placed in front of electrical panels, switch gears & high voltage equipment in order to create a safe working environment for the operators/users.

The choice of the class **must** be determined according to the maximal nominal voltage of the network.

Rigorous testing to conform to the IEC 61111:2009 standard includes:

- Puncture resistance test
- Flame retardance test

Dielectric test

- Acid resistance test
- Ageing test
- Oil resistance test

Features :

- Insulating mat for live and dead working.
- Class 0 Maximum operating voltage: 1000 V AC 1500 V DC.
- Used to cover the floor for the electrical protection of operators in electrical installations.
- Protect the workers from the ground potential.
- Must be adapted to the nominal voltage of the network supplying the installation on which it is used.
- In accordance with IEC 61111:2009 standard and to specific properties of the "C" Category (extremely low temperature folding test at – 40 °C).
- RoHS2 compliant. REACH compliant (SVHC free).
- Material: elastomer, halogen free.
- Thickness: 2.2mm +/-0.2mm.
- D bar code (Datamatrix) on marking with direct link to user guide and technical sheet.
- Storage temperature: +10°C to +21°C.
- Operating temperature: -40°C to +55°C.

Reference	Voltage		Dimensions			
	Operating Voltage AC	Operating Voltage DC	Length (mm)	Width (mm)	Thickness (mm)	Weight (kg)
MP-11/11	1 000 V	1 500 V	1 000	1 000	2,2	3
MP-11/21	1 000 V	1 500 V	1 200	1 000	2,2	3,6
MP-100/02-5	1 000 V	1 500 V	5 000	1 000	2,2	18
MP-100/02-10	1 000 V	1 500 V	10 000	1 000	2,2	30

UID : | TID : :: 01/01/1970| SID : :: 01/01/1970 | Issued :05/01/2025 02:28:37 pm

Last Modification : 05/29/2024



