





Standards IEC 61557-7 N° de nomenclature Enedis: 37.10.617

MS-152-X

Phase rotation indicator

Application:

- · Phase rotation indicator activated from 85 V.
- Signaling via the successive lighting of diodes symbolising rotation.
- Works on generating unit.

Features:

- · The diodes indicate:
 - · clockwise rotation: mark with arrow OK,
 - · Anti clockwise rotation indicated by the red arrow "INVERSE"
 - Fault: the DEFECT diode (DEFAUT) indicates an error of connection such as the cut or absence of phase or thepresence of neutral between phases

Composition:

- 3 probes IP2X with retractable protector with 1,20 flexible cable.
- 2 crocodile clamps.
- 1 carryng bag with stray.





Last Modification: 07/21/2025